

Letter No. 3156

OFFICE OF THE STATE FIRE OFFICER, BIHAR, PATNA.

From,

Ramesh Chandra.
State Fire Officer.
Bihar, Patna.

To,

Sri Sudhendu Ranjan.
Certified Architect.
Q-1. Chandj Vyapar Bhawan.

Sub:-

The views regarding proposed commercial cum residential building of below 15m in height to be constructed at Mauza- Phulwari. Dist.- Patna.

Patna Dt. 10

Sir,

Please refer to your letter no.- nil dt.- 29/09/2012 through which this aforesaid plan has been sent to us for examination, which was examined by the Fire Service committee.

During examination of the plan it was found that a B+G+4 (Total B/U area 463 sq.Mtr.) commercial cum residential building, shall be constructed on more than 40 feet wide belongs to M/S- Newton Builders Pvt Ltd. Director Sri Satish Kumar Roy S/O- Sobh Nath Roy having Plot no.-110, Khata no.- 645, Tauzi no -5486. Thana no.-38, Mauza- Phulwari, Dist- Patna.

We clear the plan after giving following advice/suggestions/ recommendations based on NBC guideline, local building by laws & the local circumstances which must be followed by concerned Architect/Developer/Land owner as the case may be.

i) **Construction:**

- The whole construction of the proposed building shall be carried out as per approved plan drawing conforming the relevant building rules of local Municipal Corporation.
- The floor area exceeds 750 m² shall be suitable compartmented by separation walls to ceiling level having at least two hours Fire resisting capacity.
- The interior finish decoration of the building shall be made low flame spread material conforming I.S. specifications.
- Provision of ventilation at the crown of the central core-duct of the building shall provide.
- Arrangements shall have to be made for sealing all the vertical ducts by the material of adequate Fire resisting capacity.

ii) **Open Space & Approach:**

- The open space surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire appliance with turning facility.
- The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting up to 20 M.T.
- The width and height of the access gates into the premises shall not be less than 4.5 M and 5M respecting abutting the road.

iii) **Stair Case:-**

- The Staircase of the building shall be enclosed type. Construction shall be made of brick / R.C.C. type having Fire resisting capacity not less than 4 hours respectively marked in the plan.
- The Staircase of the building shall have permanent vents at the top equal to 5% of the cross sectional area of the staircase enclosures and operable sashes at each floor level equal to 15% of the said cross section area shall have to be provided in the external wall of the building.
- All the Staircase of the building shall be negotiable to each other in each floor without entering into any room and shall be extended up to respective terrace. The roof of the Stair wall shall be 1M above the surrounding roof area.
- The width of the Staircases and corridor and travel distance of different categories of occupancies shall have to conform the relevant building rules.
- In case of two staircase, one must be on outer wall.