

235

M/Gmail

sanjeev verma <verma227@gmail.com>

Fwd: नक्शा रीभेलीडेट / रीएप्रूवल आवेदन जमा करने का प्रमाण जमा करने के सन्दर्भ में
1 message

Tue, Nov 2, 2021 at 3:30 PM

RERA BIHAR <rerabihar@gmail.com>
To: verma227 <verma227@gmail.com>

From: info@winsomebuilders.com
To: rerabihar@gmail.com
Cc: "RERA BIHAR" <rerabihar@gmail.com>
Sent: Tuesday, November 2, 2021 3:00:33 PM
Subject: नक्शा रीभेलीडेट / रीएप्रूवल आवेदन जमा करने का प्रमाण जमा करने के सन्दर्भ में

सेवा में
श्री मान
प्राधिकृत पदाधिकारी
भू-सम्पदा विनियामक प्राधिकरण,
बिहार, पटना

महाशय,

सविनय निवेदन के साथ उपर्युक्त विषय के संबंध में कहना है की, मेरी परियोजना जिसका नाम - **विन्सम कृपानंद इनक्लेव** है जिसका **रेरा रेजिस्ट्रेशन संख्या - BRERAP00883-2/637/R-353/2019** है का नक्शा रीभेलीडेट / रीएप्रूवल के लिए आवेदन सक्षम पदाधिकारी के पास दिनांक - **दिनांक - 21-09-2021** को जमा किया जा चुका है, जिसकी पावती की छाया प्रति इस आवेदन के साथ प्रमाण के रूप में संलग्न किया गया है जो की आपके सूचनार्थ समर्पित किया जा रहा है।

भवदीय

सुधीर कुमार



2 attachments

APPLICATION OF RERA (KRIPANAND ENCLAVE).jpg
493K

1952

1952

1952

UNITED STATES PATENT OFFICE
1952



WINSOME BUILDERS & ASSOCIATES

fit into the luxurious life you and your loved once always wanted

9338

Ref/Win/2021-22/Nov-003

सेवा मे
श्री मान
प्राधिकृत पदाधिकारी
भू-सम्पदा विनियामक प्राधिकरण,
बिहार, पटना

दिनांक 01-11-2021

विषय - नक्शा रीभेलीडेट / रीएप्रुवल आवेदन जमा करने का प्रमाण जमा करने के सन्दर्भ मे

महाशय,

सविनय निवेदन के साथ उपर्युक्त विषय के संबंध मे कहना है की, मेरी परियोजना जिसका नाम - **विन्सम कृपानंद इनक्लेभ** है जिसका रेरा रेजिस्ट्रेशन संख्या - **BRERAP00883-2/637/R-353/2019** है का नक्शा रीभेलीडेट / रीएप्रुवल के लिए आवेदन सक्षम पदाधिकारी के पास दिनांक - **21-09-2021** को जमा किया जा चुका है, जिसकी पावती की छाया प्रति इस आवेदन के साथ प्रमाण के रूप मे संलग्न किया गया है जो की आपके सूचनार्थ समर्पित किया जा रहा है।

भवदीय

Winsome Builders & Associates

Sudhir Kumar
Partner

Letter No.....1667.../

OFFICE OF THE STATE FIRE OFFICER-CUM-DIRECTOR, BIHAR, PATNA.

From,

Rattanmani Sanjeev,
State Fire Officer,
Bihar, Patna.

To,

Ar. Umashankar Kumar,
Architect,
Regd. No.- CA/2011/54023,
Hartali more, Boring caninal road, Patna.

Sub :-

Patna Dt. 12.06.2018.
The views regarding proposed fully residential building of below 15 mtr. in height to be constructed at Mauza- Jalalpur, Dist- Patna.

Sir,

Please refer to your letter no.- 106/18/Fire/Ltr. dt. - 03/04/2018 through which this aforesaid plan has been sent to us for examination, which was examined by the Fire Service committee.

During examination of the plan it was found that a B+G+3 (Total B/U area-4290.55 Sqmtr.), fully residential building, shall be constructed on 20 feet wide road belongs to Winsome Builders & Associates, Partner- Sri Sudhir Kumar, S/O- Sri Ramchandra Prasad Gupta, on having Plot no.- 371 (P), 372 (P), Khata no.-151, Tauzi no.-5524, Thana no.-22 at Mauza - Jalalpur, Dist- Patna.

We clear the plan after giving following advice/suggestions/ recommendations based on NBC guideline, local building by laws & the local circumstances which must be followed by the concerned Architect / Developer/ Land owner as the case may be.

i) **Construction :**

- a) The whole construction of the proposed building shall be carried out as per approved plan drawing conforming the relevant building rules of local Municipal Corporation as per Building Bye laws Bihar, 2014.
- b) The floor area exceeds 750 m² shall be suitably compartmented by separation walls up to ceiling level having at least two hours Fire resisting capacity.
- c) The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
- d) Provision of ventilation at the crown of the central core-duct of the building shall be provided.
- e) Arrangements shall have to be made for sealing all the vertical ducts by the materials of adequate Fire resisting capacity.

ii) **Open Space & Approach :**

- a) The open space surrounding the building shall conform the relevant building rules.
- b) The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting up to 20 M.T.
- c) The width and height of the access gates into the premises shall not be less than 4.5 M and 5M respecting abutting the road.

iii) **Stair Case :-**

- a) The Staircase of the building shall be enclosed type. Entire construction shall be made of brick / R.C.C. type having Fire resisting capacity not less than 4 hours respectively marked in the plan.
- b) The Staircase of the building shall have permanent vents at the top equal to 5% of the cross sectional area of the staircase enclosures and openable sashes at each floor level equal to 15% of the said cross section are shall have to be provided in the external wall of the building.
- c) All the Staircase of the building shall be negotiable to each other in each floor without entering into any room and shall be extended up to respective terrace. The roof of the Stair wall shall be 1M above the surrounding roof area.
- d) The width of the Staircases and corridor and travel distance of different categories of occupancies shall have to confirm the relevant building rules.
- e) In case of two staircase, one must be on outer wall.
- f) Both staircase are not went down to basement floor, for approach to basement, there should be another staircase for approach.

iv) **LIFT :-**

- a) The walls of the Lift enclosure of the building shall be at least two hours Fire resisting type respectively marked in the plan with the event at top of area not less than 0.2 m².
- b) The lift of the building shall be designed at high speed "Fire Lift" and conspicuously indicated marked in the plan.
- c) In case of failure of normal electric supply, it shall automatically trip over to alternate supply. For apartment houses these change over of supply could be done through manually operated change over switch. Alternatively, the lift shall be so wired that in case of power failure, it comes down at the ground level and comes to stand still with door open.
- d) Arrangement shall be provided for extraction of smoke in all the lift shaft by incorporation smoke venting system designed to permit 30 Air changes per hour in case of Fire and shall be of such design as to operate on actuation of sprinkler or Fire Alarm. In case of failure of normal electric supply. It shall automatically trip to alternate supply.
- e) All other requirements shall conform the I.S. specification including the communication facility in the lift cars connecting with the Fire Control Room of the building.
- v) That the basement should be equipped with automatic sprinkler's installation & must have two separate exits.
- vi) That active Fire protection system such as down comer system with landing valve and hose reel at each floor incorporated with 450 LPM pump at Terrace level, ISI marked Fire extinguishers as per relevant specification & I.S 2190/1992, F.R. check door, manual call alarm point, Fire safety luminescent sign & other Fire precautionary measures as mentioned in NBC be provided before occupancy.
- vii) That an underground water static tank of not less than 20,000 Ltrs. capacity with automatic refilling arrangements preferably on front side where Fire Brigade vehicles can reach easily & overhead water static tank of not less than 10,000 Ltrs. Capacity should be made available before occupancy.
- viii) That the internal finishing shall be non-combustible or class - I surface spread of flame.
- ix) That electric cables must be shield at each floor with intumescent coating.
- x) That Fire exit drill be carried out regularly at least twice in a year after occupation.
- xi) That the building must be constructed on at least 20 feet wide road and it is responsibility of the concerned Architect to ensure the road width because he is the passing authority.
- xii) That AMC should be given to a qualified firm or person for the maintenance of above recommended Fire equipments.
- xiii) That the setback shall be checked by the Architect / Passing authority as per the established rule. If any thing wrong, the Architect / Passing authority shall be held responsible.
- xiv) It is hereby made clear that in case of any legal dispute arising in future, in which above recommendations have not been complied, the responsibility will fall entirely upon the Developers/ Architect/ Landowner as the case may be and not on the recommending Govt. authority (i.e. the office of the State Fire Office, Bihar).
- xv) It is hereby made also clear that this office (i.e. the office of the State Fire Officer-cum-Director, Bihar, Patna) is not responsible for any legal dispute of the land upon which the proposed building shall be constructed.
- xvi) Set backs on all the sides adheres to the provisions for the fire safety as per bye laws. Whereas immediately beneath this area in the basement is adhering to the bye laws will be examined by the concerned Urban local bodies.


This shall be treated as provisional. On compliance of all the above Fire and Life Safety recommendations, this office shall be approached for necessary inspection and testing of the installation, Final in favor of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B. - Any deviation and changes the nature of use of the building in respect of the approved plan drawing without obtaining prior permission from this office, this provisional will be treated as cancelled.

The maps are being returned with sign and stamp.

Encl - As Above

Yours faithfully,


DIG HG & FS
(Rattanmani Sanjeev)
State Fire Officer
Bihar, Patna