

We suggest/advice the following Fire precautionary measures based on N.B.C guide line and the local circumstances:-

i) Construction :

- a) The whole construction of the proposed building shall be carried out as per approved plan drawing conforming the relevant building rules of local Municipal Corporation.
- b) The floor area exceeds 750 m^2 shall be suitably compartmented by separation walls up to ceiling level having at least two hours Fire resisting capacity.
- c) The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
- d) Provision of ventilation at the crown of the central core-duct of the building shall be provided.
- e) Arrangements shall have to be made for sealing all the vertical ducts by the materials of adequate Fire resisting capacity.

ii) Open Space & Approach :

- a) The open space surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire appliance with turning facility.
- b) The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting up to 20 M.T.
- c) The width and height of the access gates into the premises shall not be less than 4.5 M and 5M respecting abutting the road.

iii) Stair Case :-

- a) The Staircase of the building shall be enclosed type. Entire construction shall be made of brick / R.C.C. type having Fire resisting capacity not less than 4 hours respectively marked in the plan.
- b) The Staircase of the building shall have permanent vents at the top equal to 5% of the cross sectional area of the staircase enclosures and openable sashes at each floor level equal to 15% of the said cross section are shall have to be provided in the external wall of the building.
- c) All the Staircase of the building shall be negotiable to each other in each floor without entering into any room and shall be extended up to respective terrace. The roof of the Stair wall shall be 1M above the surrounding roof area.
- d) The width of the Staircases and corridor and travel distance of different categories of occupancies shall have to conform the relevant building rules.

iv) LIFT :-

- a) The walls of the Lift enclosure of the building shall be at least two hours Fire resisting type respectively marked in the plan with the event at top of area not less than 0.2 m^2 .
- b) The lift of the building shall be designed at high speed "Fire Lift" and conspicuously indicated marked in the plan.
- c) In case of failure of normal electric supply, it shall automatically trip over to alternate supply. For apartment houses these change over of supply could be done through manually operated change over switch. Alternatively, the lift shall be so wired that in case of power failure, it comes down at the ground level land comes to stand still with door open.
- d) Arrangement shall be provided for extraction of smoke in all the lift shaft by incorporation smoke venting system designed to permit 30 Air changes per hour in case of Fire and shall be of such design as to operate on actuation of sprinkler of Fire Alarm. In case of failure of normal electric supply. It shall automatically trip to alternate supply.
- e) All other requirements shall conform the I.S. specification including the communication facility in the lift cars connecting with the Fire Control Room of the building.
- f) That active Fire protection system such as wet cum down comer system with landing valve and hose reel at each floor incorporated with 450 LPM pump at Terrace level, ISI marked Fire extinguishers as per I.S 2190/1992, F.R. check door, manual call alarm point, Fire safety luminescent sign & other Fire precautionary measures as mentioned in NBC be provided before occupancy.
- vi) That an underground water static tank of not less than 20,000 Ltrs. capacity with automatic refilling arrangements preferably on front side where Fire Brigade vehicles can reach easily & overhead water static tank of not less than 10,000 Ltrs. capacity should be provided before occupancy.
- vii) That the internal finishing shall be non-combustible or class - I surface spread of flame.
- viii) That electric cables must be shield at each floor with intumescent coating.
- ix) That AMC should be given to a qualified firm or person for the maintenance of above recommended Fire equipments.
- x) That Fire exit drill be carried out regularly at least twice in a year after occupation.
- xi) That the building must be constructed on at least 20 feet wide road and it is responsibility of the concerned Architect to be sure of the road width because he is the passing authority.


STATE FIRE OFFICER
BIHAR, PATNA

उपरी कम्पेन प्वाइतीय स्टेट बैंक
Issuing Branch: State Bank of India (PATNA)
कॉड नं. / CODE No. 03114
Tel No. 0612-2232445

मांगडापट

DEMAND DRAFT

Key: NUKCUS
Sr. No: 893311

2	8	0	5	2	0	1	8
D	D	M	M	Y	Y	Y	Y

मॉगे जानेपर R.E.R.A., PATNA

ON DEMAND PAY

रुपये RUPEES

या उनके आदेश पर
OR ORDER

9500.00

अदा करें

AMOUNT BELOW 9501(9/4)

मूल्य प्राप्त / VALUE RECEIVED

IOI 000462721954 Key: NUKCUS

Sr. No: 893311

भारतीय स्टेट बैंक

STATE BANK OF INDIA

अवकाश राखा / DRAWEE E
कोड नं. / CODE No: 00152

CODE No: 00152

प्राधिकृत हस्ताक्षरकर्ता
AUTHORISED SIGNATORY

BRANCH MANAGER

कम्प्यूटर द्वारा मुद्रित होने पर ही वैध
VALID ONLY IF COMPUTER PRINTED

BRANCH MANAGER

97 11297000 :00002 00000 11756722 11

भारत सरकार
Government of India


सतीश कुमार
Satis Kumar
जन्म तिथि / DOB : 25/06/1961
पुरुष / Male



9686 1715 9865

आधार - आम आदमी का अधिकार

Satis Kumar

आयकर विभाग
INCOME TAX DEPARTMENT



भारत सरकार
GOVT. OF INDIA

SUBODH KUMAR

MADHU SUDAN RAI

02/02/1972


Participant Account Number


AKKPK9205D



For RERA Registration

Subodh Kumar

आयकर विभाग INCOME TAX DEPARTMENT		भारत सरकार GOVT. OF INDIA
PRAGATI PATEL BRISHIN PATEL 12/12/1973 Permanent Account Number AOMPP4463Q		 
<i>Pragati Patel</i> Signature		<i>Pragati Patel</i>



For RERA Registration
only.

Handl

आयकर विभाग
INCOME TAX DEPARTMENT



भारत सरकार
GOVT. OF INDIA

SATISH KUMAR
SAHJANAND SINGH
25/06/1961

Permanent Account Number

AIMPK4555A

Satish Kumar

Signature



Satish Kumar



LANDMARK BUILDERS & DEVELOPERS
G-2, BAIDYANATH APARTMENT, JAGDEO PATH, BAILEY ROAD, PATNA - 800 014

Patna

Ref.....

Date...05-10-2017

AUTHORISATION LETTER

This is to state that **Mr. Satish Kumar**, partner of the firm is hereby authorised to represent the firm for registration of GST, RERA, Sale Agreement, Dev. Agreement & other official documents with Govt. of India / Govt. of Bihar / Semi Govt./ Private Organisation. The above person is also authorised to sign, submit necessary papers & documents with the govt. of India / Govt. of Bihar / Semi Govt. / Private organisation.

FOR LANDMARK BUILDERS & DEVELOPERS

Pragati Patel *Satish Kumar*
PARTNERS